

DDES

King County Fire Marshal's Office

Department of Development and Environmental Services

900 Oakesdale Avenue Southwest

Renton, WA 98055-1219

(206) 296-6675

1) cc: Rita - for all needed follow up



2) cc: Colman, Elwood

IRG 14
PSF 3

Permit #

Date Req

Date Insp

2/4/02

Address

3) file

F.D.# KCA

Project Name

Operation Skyway

Phone ()

RECEIVED
KING COUNTY

Type of Inspection

A

Contact Name

FEB 04 2002

Approvals:

Corrections:

INTERNATIONAL
AIRPORT

Operation Skyway could be used as meeting room under the following conditions

1. All exits to be clear w/ 44" aisle ways

2. Any hazardous materials to be properly stored in cabinets

3. Additional exit signs to posted in North exit.

4. Can use 4 Column spaces $24 \times 24 = 576 \text{ sq. ft.}$
 $= 2304 \div 15 = 153$

5. Occupant load to be posted

6. Secure Operation Skyway Area to prevent people from moving around in Area.

Call if you have questions 206-296-6772

Thanks

Thank you in advance for your cooperation. A Reinspection will be conducted in approximately days.

Inspector

Received by

J. J. Birmingham

Page of

1773 (12/00)

Inspections are made under authority of RCW 19.27, KCC Title 17 and King County Ordinance.

KCSlip4 34150

SEA400697